



Urgent!

Fire Extinguisher Recall

Risk Alert November 2017

www.wrcip.us

Attention: WRCIP Members and Brokers

It has come to our attention the United States Consumer Product Safety Commission (CPSC) has recently issued a recall for Kidde Fire Extinguishers with plastic handles, due to failure to discharge and nozzle detachment.

For your reference, we have included the link for the recall information below. We recommend you, or your maintenance personnel, check all existing fire extinguishers to make sure they are removed and replaced, if they are a Kidde product listed in this recall. We also recommend checking all brands of fire extinguishers, as directed by the manufacturer, to make sure maintenance checks are up-to-date and that they are in proper working order.

Please do not hesitate to contact our office, or your agent, if you have any questions regarding this information, or if we can be of further assistance.

Thank you for your prompt attention to this important matter.

Link: [Kidde Fire Extinguisher Recall](#)

